

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UN718		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner CCS PROPERTIES Phone # (920)632-4815						1. Well Location Fire # (if avail.) 1048					
Mailing Address 1048 GLORY RD STE C City GREEN BAY State WI Zip Code 54304						Town of WAUTOMA Street Address or Road Name and Number STATE RD 22					
County Waushara		Co. Permit #		Notification # 41773686		Completed 10-04-2011		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) MICHAEL J JAKUBOWSKI				Lic. # 538		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W		Method Code	
Address JAKUBOWSKI WELL DRILLING WILD ROSE WI 54984				Well Plan Approval #		NE NE Section Township Range or Govt Lot # 1 19 N 10 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? TOO CLOSE TO SEPTIC Construction Type Drilled			
				Approval Date (mm-dd-yyyy)							
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3							
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock			
4		Surface		104							
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit 4in. dia... No Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)					
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
- - S -		SAND		Surface		3					
- - C -		CLAY		3		13					
- N S -		FINE SAND		13		96					
- A S -		COARSE SAND		96		104					
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly		From (ft.)		To (ft.)					
4		T & C IPSCO 257 WALL #589		Surface		100					
Dia. (in.)		Screen type, material & slot size		From (ft.)		To (ft.)					
4		STAINLESS STEEL 10 SLOT		100		104					
7. Grout or Other Sealing Material											
Method											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement					
		Surface									
9. Static Water Level 28 ft. below ground surface											
10. Pump Test Pumping level 65 ft. below surface Pumping at 12 GP for 4 Hrs. Pumping Method ?											
11. Well Is 14 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes											
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes											
13. Constructor / Supervisory Driller						Lic #		Date Signed			
MJ								10-08-2011			
Drill Rig Operator						Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Downspout/Yard Hydrant		12
Building Overhang		7	Foundation Drain to Sewer		35
			Septic or Holding, or POWTS Tank		45

Comment:

Created On: 10-31-2011

Updated On: 10-31-2011

Review Status: