

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UN936		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A															
Property Owner KOZDRON, KEN					Phone # (630)476-1099			1. Well Location				Fire # (if avail.)													
Mailing Address W2311 CO B					Town of PESHTIGO							W2311													
City PESHTIGO					State WI		Zip Code 54154					Street Address or Road Name and Number W2311 CO B													
County Marinette		Co. Permit #		Notification # 33122987			Completed 05-15-2009			Subdivision Name			Lot #		Block #										
Well Constructor (Business Name) A-1 KEY PLBG SERVICES LLC				Lic. # 6604		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.0351 °N -87.7099 °W				Method Code GCD013											
Address N3236 RIVER BEND DR PESHTIGO WI 54157				Well Plan Approval #				SE SW		Section 28		Township 30 N		Range 23 E											
Hicap Permanent Well #				Common Well #		Specific Capacity				2. Well Type New Well				of previous unique well #		constructed in									
3. Well serves # of				Hicap Well ?				Reason for replaced or reconstructed well ?				Construction Type Driven Point		Heat Exchange ___ # of drillholes		Hicap Property ?		Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE														8. Geology											
5. Drillhole Dimensions and Construction Method														9. Static Water Level				11. Well Is							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				7 ft. below ground surface				30 in. above grade							
2		Surface		28		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary				Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO				Pumping level ___ ft. below surface				Developed ? Yes							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		Pumping at ___ GP for ___ Hrs.				Disinfected ? Yes											
2		GALVANIZED				Surface		25		Pumping Method ?				Capped ? Yes											
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		12. Notified Owner of need to fill & seal ?															
2		STAINLES SEEL				25		28		Filled & Sealed Well(s) as needed?															
7. Grout or Other Sealing Material														13. Constructor / Supervisory Driller				Lic #		Date Signed					
Method														TJ				05-15-2009		Drill Rig Operator		Lic or Reg #		Date Signed	
Kind of Sealing Material														From (ft.)				To (ft.)		# Sacks Cement					
Surface														Surface				Surface		Surface					

4a. Potential Contamination Sources

Is the well located in floodplain ?

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		105	Building Overhang		3
Building Drain - Sanitary		30	Septic or Holding, or POWTS Tank		35

Comment:

Created On: 07-07-2009

Updated On: 10-22-2019

Review Status: