

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UO104		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner ALLEN, MARK						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 534 N GARFIELD ST								Town of COLBURN					
City LOMBARD						State IL		Zip Code 60148					
County Adams		Co. Permit #		Notification # 27912165		Completed 11-19-2007		Subdivision Name CSM 4786				Lot # 3	
Well Constructor (Business Name) FOSTER ENTERPRISES LTD				Lic. # 163		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.1352 °N -89.7 °W			
Address 2520 STATE RD 13 ADAMS WI 53910-9739				Well Plan Approval #		SE NE		Section 7		Township 19 N		Method Code GCD013	
				Approval Date (mm-dd-yyyy)		Range 7 E							
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type New Well				of previous unique well # constructed in			
3. Well serves 1 # of Private, potable						Hicap Well ? No		Reason for replaced or reconstructed well ?					
Heat Exchange ___ # of drillholes						Hicap Property ? No		Construction Type Jetted					
Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole						Lower Open Bedrock	
6		Surface		6		Yes Rotary - Mud Circulation						No	
2		6		46		Rotary - Air							
						Rotary - Air & Foam							
						Drill-Through Casing Hammer							
						Reverse Rotary							
						Cable-tool Bit ___ in. dia...							
						Dual Rotary							
						Temp. Outer Casing ___ in. dia							
						Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)			
- - S -		SAND						Surface		20			
- - S I		LOAMY SAND						20		32			
- A S -		COARSE SAND						32		46			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
2		SEAL ASTM A-53A THREADED & COUPLED 3.75#				Surface		42					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
1.25		CAMPBELL SS 10 SLOT				42		46					
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
PIT LOSS ADPT				Surface		6		S					
9. Static Water Level													
10 ft. below ground surface													
10. Pump Test													
Pumping level 10 ft. below surface													
Pumping at 12 GP M for 1 Hrs.													
Pumping Method ?													
11. Well Is													
14 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? No													
NONE													
13. Constructor / Supervisory Driller						Lic #		Date Signed					
DSF								11-28-2007					
Drill Rig Operator						Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Septic or Holding, or POWTS Tank		48

Comment:

Created On: 01-10-2008

Updated On: 05-04-2020

Review Status: