Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UO107

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LORING, JUDY			Phone #
Mailing Address: 1470 WASHINGTON PIKE			
City: WELLSBURG	State: WV	Zip Code: 26070	
County: Adams	Co. Permit #:	Notification #: 28079250	Completed: 11-20-2007

Well Constructor (Business Name): FOSTER ENTERPRISES LTD	Lic. #: 163	Facility ID # (Public Wells):	
Address: 2520 STATE RD 13 ADAMS WI 53910-9739		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity:	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of ADAMS				Fire # (if avail.): 1179
Street Address or Road Name and Number: 1179 DUCK CREEK DR				
Subdivision Name:			Lot #:	Block #:
Latitude / Longitude in Decimal Degree (DD): 43.9156 °N -89.8134 °W				Method Code: GCD013
NW SW or Govt Lot #:	Section: 29	Township: 17 N	Range: 6 E	

2. Well Type Replacement
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type Jetted

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	6
2	6	37

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	25
-	M	S	-	MEDIUM SAND	25	37

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	SEAL ASTM A-53A THREADED & COUPLED 3.75#	Surface	33
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	CAMPBELL SS 7 SLOT	33	37

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PITLESS ADPT	Surface	6	S

9. Static Water Level
15 ft. below ground surface

10. Pump Test
Pumping level 15 ft. below surface
Pumping at 10 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DSF		11-30-2007
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		82
Building Drain - Sanitary		24
Building Overhang		8
Clearwater Sump		29
Sewer - Building Sanitary		57
Septic or Holding, or POWTS Tank		72

Comment:

Created On: 01-10-2008 Updated On: 05-04-2020 Review Status: