Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UO915

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DRAEGER, CHERYL	Phone #
Mailing Address: 2621 HIBBARD	
City: LA CROSSE	State: WI / Zip Code: 54603
County: La Crosse	Co. Permit #: 29162 / Notification #: 30369014 / Completed: 08-15-2008
Well Constructor (Business Name): RANDY C STUHR	Lic. #: 58 / Facility ID # (Public Wells)
Address: MEDARY DRILLING CO, HOLMEN WI 54636	Well Plan Approval # / Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well # / Specific Capacity: 0.6

1. Well Location

Town of CAMPBELL

Fire # (if avail.)

Street Address or Road Name and Number: 2621 HIBBARD CT

Subdivision Name / Lot # / Block #

Latitude / Longitude in Decimal Degree (DD): 43.8671 °N -91.2688 °W

Method Code: GCD013

NW NW or Govt Lot # / Section: 18 / Township: 16 N / Range: 7 W

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: WATER SUPPLY

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	66

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 4in. dia... — No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	-	SAND & GRAVEL	Surface	66

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	ASTM A53 T&C 237 WALL 11.00 #/FT IPSCO PIPE	Surface	63
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	STAINLESS STEEL 10 SLOT	63	66

9. Static Water Level

34 ft. below ground surface

10. Pump Test

Pumping level 51 ft. below surface

Pumping at 10 GP for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NATIVE MATERIAL	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RCS		08-26-2008
Drill Rig Operator	Lic or Reg #	Date Signed
MI		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		20	Collector Sewer - San or Storm		60
Building Overhang		8	Sewer - Building Sanitary		20

Comment:

Created On: 09-29-2008 Updated On: 04-30-2020 Review Status: