Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UO917

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: THOMPSON, T	Phone #
Mailing Address: W7966 COUNTRY AVE	
City: HOLMEN	State: WI	Zip Code: 54636

County	Co. Permit #	Notification #	Completed
La Crosse	28341	30506214	08-28-2008

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
RANDY C STUHR	58	

Address: MEDARY DRILLING CO
HOLMEN WI 54636

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.7

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of HOLLAND

Fire # (if avail.): W7966

Street Address or Road Name and Number: COUNTRY AVE

Subdivision Name	Lot #	Block #
AUGUST PRAIRIE	4	2

Latitude / Longitude in Decimal Degree (DD)	Method Code
43.9774 °N -91.3039 °W	GCD013

SE NW or Govt Lot #	Section	Township	Range
	2	17 N	8 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
WATER SUPPLY

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	129

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 4in. dia... — No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	-	SAND & GRAVEL	Surface	129

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	ASTM-A53 T&C 237 WALL 11.00#/FT IPSCO PIPE	Surface	126
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	STAINLESS STEEL 10 SLOT	126	129

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NATIVE MATERIAL	Surface		

9. Static Water Level
81 ft. below ground surface

10. Pump Test
Pumping level 98 ft. below surface
Pumping at 12 GP for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RCS		09-03-2008
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MI		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100
Building Drain - Sanitary		30

Type	Qualifier	Distance
Building Overhang		15
Sewer - Building Sanitary		30
Septic or Holding, or POWTS Tank		75

Comment:

Created On: 09-29-2008 Updated On: 04-30-2020 Review Status: