

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UP557		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner KRAMER, DENNIS						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address N844 OAKRIDGE DR						Town of ASHIPUN															
City OCONOMOWOC						State WI		Zip Code 53066													
County Dodge		Co. Permit #		Notification # 29250050		Completed 05-19-2008		Subdivision Name HICKORY RIDGE EST				Lot # Block #									
Well Constructor (Business Name) FREDERICK F KUCK				Lic. # 593		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.22273 °N -88.5118 °W				Method Code GPS008							
Address KUCK WELL DRLG & PUMP SERV NEOSHO WI 53059-9728				Well Plan Approval #		NE NW Section Township Range or Govt Lot # 29 9 N 17 E				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
						Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 4																	
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		7		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				No		T - P -		BROWN HARDPAN		Surface		21			
6		7		159								T - P L		BROWN HARDPAN W/LIMESTONE BOULDERS		21		79			
												- Q H -		SOFT CAVING SHALE		79		123			
												K H H -		HARD BLACK SHALE		123		159			
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		117 ft. below ground surface				12 in. above grade							
6		19.45 .280 T/C ASTM A53 WHEATLAND				Surface		123		10. Pump Test Pumping level 122 ft. below surface Pumping at 20 GP M for 5 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
7. Grout or Other Sealing Material Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement CLAY SLURRY W/BENTONITE CRUMBLES Surface 7 S														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?							
13. Constructor / Supervisory Driller Lic # Date Signed FK 05-19-2008 Drill Rig Operator Lic or Reg # Date Signed FK 05-19-2008																					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		7	Collector Sewer - San or Storm		115
Clearwater Sump		15	Foundation Drain to Clearwater		9
			Sewer - Building Sanitary		60

Comment:

Created On: 07-15-2008

Updated On: 07-15-2008

Review Status: