

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UQ786		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner CERANSKE, BRUCE						Phone # (715)467-2558		1. Well Location				Fire # (if avail.)									
Mailing Address E664 STATE RD 54						Town of WAUPACA						E4172									
City WAUPACA						State WI		Zip Code 54981				Street Address or Road Name and Number E4172 STATE RD 54 & 22									
County Waupaca		Co. Permit #		Notification # 6978873001		Completed 01-16-2018		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) WILLIAM VETTER				Lic. # 6351		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.35778 °N -89.01965 °W				Method Code GPS008							
Address 1036 TOWNSEND RD WAUPACA WI 54981				Well Plan Approval #		NW NW		Section 26		Township 22 N		Range 12 E									
				Approval Date (mm-dd-yyyy)		or Govt Lot #															
Hicap Permanent Well #		Common Well #		Specific Capacity 4.2		2. Well Type New Well															
3. Well serves 1 # of GREENHOUSE Non-community Heat Exchange ___ # of drillholes						Hicap Well ? No		Reason for replaced or reconstructed well ?													
						Hicap Property ? No															
						Hicap Potable ?				Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.) 6		From (ft.) Surface		To (ft.) 40		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
						Rotary - Mud Circulation						O H C C		CLAY		Surface		7			
						Rotary - Air						T M S S		SAND		7		30			
						Rotary - Air & Foam						T W S G		SAND & GRAVEL		30		40			
						Drill-Through Casing Hammer															
						Reverse Rotary															
						Yes Cable-tool Bit 6in. dia...				No											
						Dual Rotary															
						Temp. Outer Casing ___ in. dia															
						Removed? ___ depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.) 6		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) Surface		To (ft.) 35		20 ft. below ground surface				18 in. above grade							
		STEEL WELDED JOINT. WHEATLAND 18.97 PR FT 6.625 X 280 A53 GRB								10. Pump Test				Developed ? Yes							
										Pumping level 26 ft. below surface				Disinfected ? Yes							
Dia. (in.) 6		Screen type, material & slot size				From (ft.) 35		To (ft.) 40		Pumping at 25 GP M for 4 Hrs.				Capped ? Yes							
		S.S. 18 SLOT JOHNSON								Pumping Method ?											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?							
Method MOUNDED														Filled & Sealed Well(s) as needed? N/A							
Kind of Sealing Material		From (ft.) Surface		To (ft.) 7		# Sacks Cement 3 S															
BENTONITE																					
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														WV						01-16-2018	
														Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		30

Comment:

Created On: 03-27-2018

Updated On: 05-08-2020

Review Status: