Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UQ786

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CERANSKE, BRUCE	Phone #: (715)467-2558
Mailing Address: E664 STATE RD 54	
City: WAUPACA	State: WI — Zip Code: 54981
County: Waupaca	Co. Permit #:
Notification #: 6978873001	Completed: 01-16-2018
Well Constructor (Business Name): WILLIAM VETTER	Lic. #: 6351
Facility ID # (Public Wells):	
Address: 1036 TOWNSEND RD WAUPACA WI 54981	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 4.2	

1. Well Location

Town of WAUPACA	Fire # (if avail.): E4172
Street Address or Road Name and Number: E4172 STATE RD 54 & 22	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.35778 °N -89.01965 °W	Method Code: GPS008
NW NW or Govt Lot #	Section: 26 — Township: 22 N — Range: 12 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of GREENHOUSE

Non-community

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	40

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 6in. dia... — No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
O	H	C	C	CLAY	Surface	7
T	M	S	S	SAND	7	30
T	W	S	G	SAND & GRAVEL	30	40

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL WELDED JOINT. WHEATLAND 18.97 PR FT 6.625 X 280 A53 GRB	Surface	35
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	S.S. 18 SLOT JOHNSON	35	40

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 26 ft. below surface

Pumping at 25 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface	7	3 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

N/A

13. Constructor / Supervisory Driller	Lic #	Date Signed
WV		01-16-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		30

Comment:

Created On: 03-27-2018 Updated On: 05-08-2020 Review Status: