

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UQ787		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner CHAPMAN, MARK						Phone # (262)305-3348		1. Well Location				Fire # (if avail.)			
Mailing Address 4717 LIME RIDGE RD						Town of DAYTON						N1367			
City WEST BEND						State WI		Zip Code 53095				Street Address or Road Name and Number N1367 W STRATTON LAKE RD			
County Waupaca		Co. Permit #		Notification # 6959241401		Completed 01-30-2018		Subdivision Name STRATTON ACS				Lot # 3		Block #	
Well Constructor (Business Name) WILLIAM VETTER				Lic. # 6351		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.28898 °N -89.18482 °W				Method Code OTH001	
Address 1036 TOWNSEND RD WAUPACA WI 54981				Well Plan Approval #		SE SE		Section 17		Township 21 N		Range 11 E			
				Approval Date (mm-dd-yyyy)		or Govt Lot #									
Hicap Permanent Well #		Common Well #		Specific Capacity 6.3		2. Well Type New Well				of previous unique well # constructed in					
3. Well serves 1 # of Private, potable				Hicap Well ? No		Reason for replaced or reconstructed well ?									
Heat Exchange ___ # of drillholes				Hicap Property ? No											
				Hicap Potable ?		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		60											
						Rotary - Mud Circulation									
						Rotary - Air									
						Rotary - Air & Foam									
						Drill-Through Casing Hammer									
						Reverse Rotary									
						<u>Yes</u> Cable-tool Bit 6in. dia...				<u>No</u>					
						Dual Rotary									
						Temp. Outer Casing ___ in. dia									
						Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
T Q S S				SAND				Surface		50					
T W S G				WATER BEARING SAND & GRAVEL				50		60					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		STEEL WELDED JOINT, WHEATLAND 18.97 PD PER FT 6.625 X 280 A53 GR B				Surface		57							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
6		18 SLOT JOHNSON S.S.				57		60							
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
BENTONITE				Surface		5		2 S							
9. Static Water Level															
26 ft. below ground surface															
10. Pump Test															
Pumping level 30 ft. below surface															
Pumping at 25 GP M for 4 Hrs.															
Pumping Method ?															
11. Well Is															
16 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? N/A															
13. Constructor / Supervisory Driller															
WV				Lic #		Date Signed									
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		50	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 02-19-2018

Updated On: 05-08-2020

Review Status: