Well Construction Report
WISCONSIN UNIQUE WELL NUMBER US214

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	SARBACHER, DONNA
Phone #	(608)233-1101
Mailing Address	2745 KENDALL AVE
City	MADISON
State	WI
Zip Code	53705

County	Co. Permit #	Notification #	Completed
Adams		30313802	08-21-2008

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
DAVID S FOSTER	77	

Address 2522 STATE RD 13
ADAMS WI 53910-9739

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.6

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Fire # (if avail.) 1134

Town of BIG FLATS

Street Address or Road Name and Number
S BUTTERCUP CT

Subdivision Name	Lot #	Block #
GREEN ACRES	40	

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.077	°N	-89.7994	°W	GCD013

SE	NE	Section	Township	Range
or Govt Lot #		32	19 N	6 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NO WATER

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	72

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	26
-	-	X	-	CLAY & SAND MIX	26	32
-	-	C	-	CLAY	32	40
-	N	S	-	FINE SAND	40	60
-	M	S	-	MEDIUM SAND	60	72

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	PW EAGLE SDR21 PVC ASTM F480	Surface	69
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	10 SLOT JOHNSON SS	69	72

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
HIGH SOLIDS BENT	Surface	60	S

9. Static Water Level
36 ft. below ground surface

10. Pump Test
Pumping level 63 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
13 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DSF		
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		9

Comment:

Created On: 09-19-2008 Updated On: 05-04-2020 Review Status: