

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				US214		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner SARBACHER, DONNA Phone # (608)233-1101						1. Well Location				Fire # (if avail.) 1134							
Mailing Address 2745 KENDALL AVE						Town of BIG FLATS				Street Address or Road Name and Number S BUTTERCUP CT							
City MADISON			State WI		Zip Code 53705		Subdivision Name GREEN ACRES			Lot # 40	Block #						
County Adams		Co. Permit #		Notification # 30313802		Completed 08-21-2008		Latitude / Longitude in Decimal Degree (DD) 44.077 °N -89.7994 °W			Method Code GCD013						
Well Constructor (Business Name) DAVID S FOSTER				Lic. # 77	Facility ID # (Public Wells)		SE NE Section Township Range or Govt Lot # 32 19 N 6 E		2. Well Type Replacement of previous unique well # constructed in								
Address 2522 STATE RD 13 ADAMS WI 53910-9739				Well Plan Approval #		Approval Date (mm-dd-yyyy)		Reason for replaced or reconstructed well ? NO WATER									
Hicap Permanent Well #			Common Well #		Specific Capacity 0.6		Construction Type Drilled										
3. Well serves 1 # of Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method						8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
8		Surface		72		Yes Rotary - Mud Circulation No Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)				- - S - SAND - - X - CLAY & SAND MIX - - C - CLAY - N S - FINE SAND - M S - MEDIUM SAND		Surface		26 26 32 40 60 72			
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		36 ft. below ground surface				13 in. above grade			
4		PW EAGLE SDR21 PVC ASTM F480				Surface		69		10. Pump Test				Developed ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 63 ft. below surface				Disinfected ? Yes			
4		10 SLOT JOHNSON SS				69		72		Pumping at 15 GP M for 1 Hrs.				Capped ? Yes			
7. Grout or Other Sealing Material						Pumping Method ?											
Method						12. Notified Owner of need to fill & seal ?											
Kind of Sealing Material			From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?						Yes		
HIGH SOLIDS BENT			Surface		60		S										
						13. Constructor / Supervisory Driller				Lic #		Date Signed					
						DSF											
						Drill Rig Operator				Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		9

Comment:

Created On: 09-19-2008

Updated On: 05-04-2020

Review Status: