Well Construction Report
WISCONSIN UNIQUE WELL NUMBER US216

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WALLNER, BRANDON	Phone #
Mailing Address: 1703 13TH DR	
City: FRIENDSHIP	State: WI — Zip Code: 53934
County: Adams	Co. Permit #: — Notification #: 30594111 — Completed: 09-05-2008
Well Constructor (Business Name): DAVID S FOSTER	Lic. #: 77 — Facility ID # (Public Wells):
Address: 2522 STATE RD 13 ADAMS WI 53910-9739	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.4

1. Well Location

Town of PRESTON

Fire # (if avail.):

Street Address or Road Name and Number: 11TH AVE

Subdivision Name	Lot #	Block #
CSM 5011	2	

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NE or Govt Lot #	NE	Section	Township	Range
		17	18 N	6 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	84

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	16
-	-	C	-	CLAY	16	22
-	-	X	-	CLAY & SAND MIX	22	28
-	-	C	-	CLAY	28	36
-	N	S	-	FINE SAND	36	60
-	A	Y	-	COARSE SAND & GRAVEL	60	84

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	PW EAGLE SDR 21 ASTM F480	Surface	81
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	JOHNSON SS 12 SLOT	81	84

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
HIGH SOLIDS BENT	Surface	75	8 S

9. Static Water Level

24 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 15 GP for 1 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
DSF		
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		66	Building Overhang		16
			Wastewater Sump		102

Comment:

Created On: 10-30-2008 Updated On: 10-30-2008 Review Status: