

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				US216		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner WALLNER, BRANDON						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 1703 13TH DR						Town of PRESTON									
City FRIENDSHIP						State WI		Zip Code 53934				Street Address or Road Name and Number 11TH AVE			
County Adams		Co. Permit #		Notification # 30594111		Completed 09-05-2008		Subdivision Name CSM 5011				Lot # 2		Block #	
Well Constructor (Business Name) DAVID S FOSTER				Lic. # 77		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code	
Address 2522 STATE RD 13 ADAMS WI 53910-9739				Well Plan Approval #		NE NE		Section 17		Township 18 N		Range 6 E		or Govt Lot #	
Approval Date (mm-dd-yyyy)				Hicap Permanent Well #		Common Well #		Specific Capacity 0.4				2. Well Type New Well			
Hicap Property ? No				Hicap Potable ?		Reason for replaced or reconstructed well ?				of previous unique well # constructed in					
Heat Exchange ___ # of drillholes				Hicap Well ? No		Construction Type Drilled				Reason for replaced or reconstructed well ?					
3. Well serves 1 # of Private, potable														Hicap Well ? No	
Heat Exchange ___ # of drillholes														Hicap Potable ?	
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
8		Surface		84		Yes Rotary - Mud Circulation No Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)				To (ft.)			
- - S -				SAND				Surface				16			
- - C -				CLAY				16				22			
- - X -				CLAY & SAND MIX				22				28			
- - C -				CLAY				28				36			
- N S -				FINE SAND				36				60			
- A Y -				COARSE SAND & GRAVEL				60				84			
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
4		PW EAGLE SDR 21 ASTM F480				Surface		81							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
4		JOHNSON SS 12 SLOT				81		84							
7. Grout or Other Sealing Material															
Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement HIGH SOLIDS BENT Surface 75 8 S															
9. Static Water Level 24 ft. below ground surface															
10. Pump Test Pumping level 60 ft. below surface Pumping at 15 GP for 1 Hrs. Pumping Method ?															
11. Well Is 18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No NONE															
13. Constructor / Supervisory Driller Lic # Date Signed DSF Drill Rig Operator Lic or Reg # Date Signed															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		66	Building Overhang		16
			Wastewater Sump		102

Comment:

Created On: 10-30-2008

Updated On: 10-30-2008

Review Status: