Well Construction Report
WISCONSIN UNIQUE WELL NUMBER US217

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	BEZEMEK, ROBERT
Phone #	
Mailing Address	PO BOX 264
City	WAUNAKEE
State	WI
Zip Code	53597
County	Adams
Co. Permit #	
Notification #	30659370
Completed	09-10-2008
Well Constructor (Business Name)	DAVID S FOSTER
Lic. #	77
Facility ID # (Public Wells)	
Address	2522 STATE RD 13 ADAMS WI 53910-9739
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	0.9

1. Well Location

Town of PRESTON	
Fire # (if avail.)	1714
Street Address or Road Name and Number	1714 11TH AVE
Subdivision Name	CSM 3733
Lot #	3
Block #	
Latitude / Longitude in Decimal Degree (DD)	44.0079 °N -89.797 °W
Method Code	GCD013
NW or Govt Lot #	NW
Section	28
Township	18 N
Range	6 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

DRAIN TILE TO CLOSE TO OLD ONE

Construction Type Driven Point

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	6
2	6	57

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	N	S	-	FINE SAND	Surface	15
-	-	C	-	CLAY	15	35
-	N	S	-	FINE SAND	35	45
-	M	S	-	MEDIUM SAND	45	57

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	SEAH ASTM A-53A 3.75# THREADED & COUPLED	Surface	53
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	CAMPBELL SS 10 SLOT	53	57

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PITLESS ADPT	Surface	6	

9. Static Water Level

16 ft. below ground surface

10. Pump Test

Pumping level 30 ft. below surface

Pumping at 12 GP for 1 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DSF		09-10-2008
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		140
Building Drain - Sanitary		10
Building Overhang		6
Clearwater Sump		30
Foundation Drain to Clearwater		9
Wastewater Sump		30
Sewer - Building Sanitary		32
Septic or Holding, or POWTS Tank		48

Comment:

Created On: 09-29-2008 Updated On: 05-04-2020 Review Status: