

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				US246		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner PULTZ, LARRY						Phone # (715)453-5802		1. Well Location				Fire # (if avail.)											
Mailing Address PO BOX 141						Town of SKANAWAN						3330											
City TOMAHAWK						State WI		Zip Code 54487				Street Address or Road Name and Number GRUNDY RD											
County Lincoln		Co. Permit #		Notification # 30389757		Completed 08-26-2008		Subdivision Name				Lot # Block #											
Well Constructor (Business Name) NEHLS & WEBSTER WD INC /NOKOMIS DIV				Lic. # 5842		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.451 °N -89.5909 °W				Method Code GCD013									
Address PO BOX 1403 RHINELANDER WI 54501				Well Plan Approval #		NE NE		Section 10		Township 34 N		Range 7 E											
				Approval Date (mm-dd-yyyy)		or Govt Lot #																	
Hicap Permanent Well #		Common Well #		Specific Capacity 0.2		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled																	
3. Well serves 1 # of Private, potable				Hicap Well ? No																			
Heat Exchange ___ # of drillholes				Hicap Property ? No																			
				Hicap Potable ?																			
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)							
6		Surface		122		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				- - X G		SAND, CLAY & GRAVEL		Surface		31							
										- - Z -		CLAY & GRAVEL		31		48							
										- - Z G		CLAY GRAVEL & BOULDER		48		91							
										- - C -		CLAY		91		109							
										K Q - -		BLACK GRANITE		109		122							
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		20 ft. below ground surface				18 in. above grade									
6		PE WHEATLAND 18.97 A53				Surface		109		10. Pump Test				Developed ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 80 ft. below surface				Disinfected ? Yes									
										Pumping at 10 GP M for 1 Hrs.				Capped ? Yes									
										Pumping Method ?													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?									
Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement GRANULAR Surface 20 2 S														Filled & Sealed Well(s) as needed?									
														13. Constructor / Supervisory Driller Lic # Date Signed PW 08-27-2008 Drill Rig Operator Lic or Reg # Date Signed									

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 09-19-2008

Updated On: 06-15-2020

Review Status: