

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				US247		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner OSCAR, TOM Phone # (608)838-3489						1. Well Location				Fire # (if avail.)			
Mailing Address 5602 LEANNE LN						Town of SKANAWAN				3320			
City MC FARLAND State WI Zip Code 53558						Street Address or Road Name and Number GRUNDY RD							
County Lincoln		Co. Permit #		Notification # 30428936		Completed 08-27-2008		Subdivision Name		Lot #	Block #		
Well Constructor (Business Name) NEHLS & WEBSTER WD INC /NOKOMIS DIV				Lic. # 5842	Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.451 °N -89.5903 °W			Method Code GCD013			
Address PO BOX 1403 RHINELANDER WI 54501				Well Plan Approval #		NE	NE	Section 10	Township 34 N	Range 7 E			
				Approval Date (mm-dd-yyyy)		or Govt Lot #	10	34 N	7 E				
Hicap Permanent Well #		Common Well #		Specific Capacity 1.7		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled							
3. Well serves 1 # of Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method						8. Geology							
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole			Lower Open Bedrock	Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)	To (ft.)		
6	Surface	136	Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)				-	X	-	SAND & CLAY	Surface	38	
						-	Z	-	CLAY & GRAVEL	38	134		
						-	G	-	GRAVEL	134	136		
						-	Q	-	GRANITE	136	136		
6. Casing, Liner, Screen						9. Static Water Level			11. Well Is				
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.)	To (ft.)	16 ft. below ground surface			18 in. above grade				
6	PE WHEATLAND 18.97 A53			Surface	136	10. Pump Test			Developed ? Yes				
Dia. (in.)	Screen type, material & slot size			From (ft.)	To (ft.)	Pumping level 40 ft. below surface			Disinfected ? Yes				
						Pumping at 40 GP M for 1 Hrs.			Capped ? Yes				
						Pumping Method ?							
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?							
Method						Filled & Sealed Well(s) as needed?							
Kind of Sealing Material		From (ft.)	To (ft.)	# Sacks Cement									
GRANULAR		Surface	25	2 S									
						13. Constructor / Supervisory Driller			Lic #	Date Signed			
						PW				08-27-2008			
						Drill Rig Operator			Lic or Reg #	Date Signed			

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment: 1ST CONSTRUCTION WRITTEN IN SECT. 4

Created On: 09-19-2008

Updated On: 06-15-2020

Review Status: