Well Construction Report
WISCONSIN UNIQUE WELL NUMBER US248

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ODEGAARD, SYLVIA	Phone #: (715)453-5424
Mailing Address: 2833 PRAIRIE LAKE RD	
City: TOMAHAWK	State: WI Zip Code: 54487

County	Co. Permit #	Notification #	Completed
Oneida		30431036	09-03-2008

Well Constructor (Business Name): NEHLS & WEBSTER WD INC /NOKOMIS DIV	Lic. #: 5842
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: PO BOX 1403 RHINELANDER WI 54501	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 0.6	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Fire # (if avail.): 2833

Town of NOKOMIS

Street Address or Road Name and Number: PRAIRIE LAKE RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 45.6006 °N -89.7568 °W
Method Code: GCD013

SE	SE	Section	Township	Range
or Govt Lot #		17	36 N	6 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	39

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	Q	S	-	CAVING SAND	Surface	39
-	-	X	-	SAND & CLAY	39	39

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PE IPSCO 18.97 A53	Surface	36
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	SS NO 7	36	39

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
14 ft. below ground surface

10. Pump Test
Pumping level 30 ft. below surface
Pumping at 10 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
PW		09-03-2008
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		115	Septic or Holding, or POWTS Tank		85

Comment:

Created On: 09-29-2008 Updated On: 06-30-2020 Review Status: