Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UT771

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KIZEWSKI, BOB			Phone #
Mailing Address: 3821 BROOKWOOD LN			
City: WISCONSIN RAPIDS	State: WI	Zip Code: 54494	
County: Wood	Co. Permit #:	Notification #: 41055304	Completed: 08-11-2011

1. Well Location

Town of GRAND RAPIDS

Fire # (if avail.)

Street Address or Road Name and Number: 3821 BROOKWOOD LN

Subdivision Name	Lot #	Block #
BROOKWOOD EST		

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
ROTH PLBG & WELL DRLG	5857	

Latitude / Longitude in Decimal Degree (DD): 44.3584 °N -89.7786 °W

Method Code: GCD013

Address: 618 HWY 73S, NEKOOSA WI 54457

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

NE	SW	Section	Township	Range
or Govt Lot #		27	22 N	6 E

2. Well Type New Well

of previous unique well #: constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		6.7

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	41.6

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	A	S	-	CRS SD	Surface	38
-	A	Y	-	CRS SD & GR	38	41.6

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6.625	BARZEL A53 6.625X .280 GRBE HEAT 123633 WELDED	Surface	37.6
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	JOHNSON 12 SLOT	37.6	41.6

9. Static Water Level

22.6 ft. below ground surface

10. Pump Test

Pumping level 25.6 ft. below surface

Pumping at 20 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
KR		08-20-2011
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Wastewater Sump		26
Building Drain - Sanitary		24	Sewer - Building Sanitary		25
Building Overhang		14	Septic or Holding, or POWTS Tank		47

Comment:

Created On: 09-22-2011 Updated On: 05-05-2020 Review Status: