

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UT771		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner KIZEWSKI, BOB						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 3821 BROOKWOOD LN						Town of GRAND RAPIDS															
City WISCONSIN RAPIDS						State WI		Zip Code 54494				Street Address or Road Name and Number 3821 BROOKWOOD LN									
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #							
Wood				41055304		08-11-2011		BROOKWOOD EST													
Well Constructor (Business Name) ROTH PLBG & WELL DRLG				Lic. # 5857		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.3584 °N -89.7786 °W				Method Code GCD013							
Address 618 HWY 73S NEKOOSA WI 54457				Well Plan Approval #				NE SW		Section 27		Township 22 N		Range 6 E							
				Approval Date (mm-dd-yyyy)				or Govt Lot #													
Hicap Permanent Well #				Common Well #		Specific Capacity 6.7				2. Well Type New Well				of previous unique well #		constructed in					
Reason for replaced or reconstructed well ?																					
3. Well serves 1 # of				Hicap Well ? No				Private, potable				Hicap Property ? No									
Heat Exchange ___ # of drillholes				Hicap Potable ?				Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		41.6		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								- A S -		CRS SD		Surface		38	
														- A Y -		CRS SD & GR		38		41.6	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		22.6 ft. below ground surface				18 in. above grade							
6.625		BARZEL A53 6.625X .280 GRBE HEAT 123633 WELDED				Surface		37.6		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 25.6 ft. below surface				Disinfected ? Yes							
6		JOHNSON 12 SLOT				37.6		41.6		Pumping at 20 GP M for 2 Hrs.				Capped ? Yes							
										Pumping Method ?											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?							
Method														Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement													
				Surface																	
13. Constructor / Supervisory Driller								Lic #		Date Signed											
KR										08-20-2011											
Drill Rig Operator								Lic or Reg #		Date Signed											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Wastewater Sump		26
Building Drain - Sanitary		24	Sewer - Building Sanitary		25
Building Overhang		14	Septic or Holding, or POWTS Tank		47

Comment:

Created On: 09-22-2011

Updated On: 05-05-2020

Review Status: