Well Construction Report
WISCONSIN UNIQUE WELL NUMBER

UT826

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MALCORE, MATT	Phone #: (920)866-9464
Mailing Address: 4021 GRAVEL PIT RD	
City: NEW FRANKEN	State: WI — Zip Code: 54229
County: Brown	Co. Permit #:
Notification #: 31332154	Completed: 11-19-2008
Well Constructor (Business Name): KENNETH GREGORICH	Lic. #: 6985
Facility ID # (Public Wells):	
Address: 5861 MARY'S RD, NEW FRANKEN WI 54229	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.7	

1. Well Location

Town of EATON

Fire # (if avail.):

Street Address or Road Name and Number: 2595 ALLEN RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 44.453 °N -87.8331 °W

Method Code: GCD013

SW NE or Govt Lot #	Section	Township	Range
	21	23 N	22 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	61
6	61	103

Upper Enlarged Drillhole / Lower Open Bedrock

- Yes — Rotary - Mud Circulation ..... — No
- Rotary - Air .....
- No — Rotary - Air & Foam ..... — Yes
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	25
-	-	C	G	CLAY & STONES	25	50
-	-	G	-	GRAVEL	50	61
-	-	L	-	LIMESTONE	61	103

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND STEEL P.E. 18.97 PER FT. BLACK NEW ASTM-A-53-B MADE IN USA	Surface	61
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

17 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 40 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	61	S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
KG		11-19-2008
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100
Building Overhang		15
Clearwater Sump		15
Foundation Drain to Clearwater		15
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 01-05-2009 Updated On: 11-21-2019 Review Status: