

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UT826		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner MALCORE, MATT						Phone # (920)866-9464		1. Well Location				Fire # (if avail.)			
Mailing Address 4021 GRAVEL PIT RD						Town of EATON						Street Address or Road Name and Number			
City NEW FRANKEN						State WI		Zip Code 54229				2595 ALLEN RD			
County Brown		Co. Permit #		Notification # 31332154		Completed 11-19-2008		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) KENNETH GREGORICH				Lic. # 6985		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.453 °N -87.8331 °W				Method Code GCD013	
Address 5861 MARY'S RD NEW FRANKEN WI 54229				Well Plan Approval #				SW NE		Section 21		Township 23 N		Range 22 E	
				Approval Date (mm-dd-yyyy)				or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity 1.7				2. Well Type New Well					
Reason for replaced or reconstructed well ?															
3. Well serves 1 # of Private, potable				Hicap Well ? No				Hicap Property ? No				Construction Type Drilled			
Heat Exchange ___ # of drillholes				Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
8.75		Surface		61		Yes Rotary - Mud Circulation No									
6		61		103		No Rotary - Air Yes									
						No Rotary - Air & Foam Yes									
						Drill-Through Casing Hammer									
						Reverse Rotary									
						Cable-tool Bit ___ in. dia...									
						Dual Rotary									
						Temp. Outer Casing ___ in. dia									
						Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
- - C -				CLAY				Surface		25					
- - C G				CLAY & STONES				25		50					
- - G -				GRAVEL				50		61					
- - L -				LIMESTONE				61		103					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		WHEATLAND STEEL P.E. 18.97 PER FT. BLACK NEW ASTM-A-53-B MADE IN USA				Surface		61							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
CLAY SLURRY				Surface		61		S							
9. Static Water Level															
17 ft. below ground surface															
10. Pump Test															
Pumping level 40 ft. below surface															
Pumping at 40 GP M for 1 Hrs.															
Pumping Method ?															
11. Well Is															
18 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
KG				11-19-2008											
Drill Rig Operator				Lic or Reg #				Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Clearwater Sump		15
Building Overhang		15	Foundation Drain to Clearwater		15
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 01-05-2009

Updated On: 11-21-2019

Review Status: