

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UT828		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner DONOVA, MIKE						Phone # (920)606-3257		1. Well Location				Fire # (if avail.)					
Mailing Address PO BOX 154						Town of GREEN BAY											
City LUXEMBURG						State WI		Zip Code 54217				Street Address or Road Name and Number 6213 SIEDL RD					
County Brown		Co. Permit #		Notification # 31595024		Completed 12-02-2008		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) KENNETH GREGORICH				Lic. # 6985		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.53107 °N -87.76945 °W				Method Code GPS008					
Address 5861 MARY'S RD NEW FRANKEN WI 54229				Well Plan Approval #		SW SE Section Township Range or Govt Lot # 24 24 N 22 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 0.4													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			8. Geology								
8.75 Surface 41			Rotary - Mud Circulation						Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.)								
6 41 283			<u>Yes</u> Rotary - Air <u>No</u>						- - C - CLAY Surface 12								
			<u>No</u> Rotary - Air & Foam <u>Yes</u>						- - L - LIMESTONE 12 283								
			Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary														
			<u>Yes</u> Temp. Outer Casing 10in. dia														
			<u>Yes</u> Removed? ___ depth ft. (If NO explain on back side)														
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level		11. Well Is					
6		WHEATLAND STEEL P.E. 18.97 PER FT. BLACK NEW ASTM-A-55-B MADE IN USA				Surface		41		49 ft. below ground surface		18 in. above grade					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test		Developed ? Yes Disinfected ? Yes Capped ? Yes					
										Pumping level 120 ft. below surface Pumping at 30 GP M for 1 Hrs. Pumping Method ?							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?					
Method PRESSURE PUMPED												Filled & Sealed Well(s) as needed? Yes					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement											
PORTLAND CEMENT TRIMIE PIPE		Surface		41		10 S											
												13. Constructor / Supervisory Driller		Lic #		Date Signed	
												KG				12-02-2008	
												Drill Rig Operator		Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Clearwater Sump		50
Building Overhang		50	Foundation Drain to Sewer		50
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 01-20-2009

Updated On: 01-20-2009

Review Status: