

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UT829		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner KLAUBAUF, TONY						Phone # (920)371-0772		1. Well Location				Fire # (if avail.)					
Mailing Address 2428 S MICHIELS RD						Town of EATON						Street Address or Road Name and Number 2428 S MICHIELS RD					
City DENMARK			State WI		Zip Code 54208			Subdivision Name				Lot #		Block #			
County Brown		Co. Permit #		Notification # 31602565		Completed 12-03-2008		Latitude / Longitude in Decimal Degree (DD) 44.456 °N -87.8068 °W				Method Code GCD013					
Well Constructor (Business Name) KENNETH GREGORICH				Lic. # 6985		Facility ID # (Public Wells)		NE NE Section Township Range or Govt Lot # 22 23 N 22 E		2. Well Type New Well			of previous unique well # constructed in				
Address 5861 MARY'S RD NEW FRANKEN WI 54229				Well Plan Approval #		Approval Date (mm-dd-yyyy)		Reason for replaced or reconstructed well ?									
Hicap Permanent Well #			Common Well #		Specific Capacity 0.5		Construction Type Drilled										
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
8.75		Surface		72		Yes Rotary - Mud Circulation		No		- - C -		CLAY		Surface		30	
6		72		123		No Rotary - Air				- - Z -		CLAY & STONES		30		72	
						No Rotary - Air & Foam		Yes		- - L -		LIMESTONE		72		123	
						Drill-Through Casing Hammer											
						Reverse Rotary											
						Cable-tool Bit ___ in. dia...											
						Dual Rotary											
						Temp. Outer Casing ___ in. dia											
						Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		42 ft. below ground surface				11. Well Is 18 in. above grade			
6		WHEATLAND STEEL P.E. 18.97 PER FT. BLACK NEW ASTM-A-53-B MADE IN USA				Surface		72		10. Pump Test Pumping level 80 ft. below surface Pumping at 20 GP M for 1 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
7. Grout or Other Sealing Material Method												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement									
CLAY SLURRY				Surface		72		S									
												13. Constructor / Supervisory Driller Lic # Date Signed KG Drill Rig Operator Lic or Reg # Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Clearwater Sump		30
Building Overhang		30	Foundation Drain to Clearwater		30
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 01-20-2009

Updated On: 11-21-2019

Review Status: