Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UT829

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KLAUBAUF, TONY	Phone #: (920)371-0772
Mailing Address: 2428 S MICHIELS RD	
City: DENMARK	State: WI — Zip Code: 54208
County: Brown	Co. Permit #:
Notification #: 31602565	Completed: 12-03-2008
Well Constructor (Business Name): KENNETH GREGORICH	Lic. #: 6985
Facility ID # (Public Wells):	
Address: 5861 MARY'S RD, NEW FRANKEN WI 54229	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.5	

1. Well Location

Town of EATON

Fire # (if avail.):

Street Address or Road Name and Number: 2428 S MICHIELS RD

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): 44.456 °N -87.8068 °W

Method Code: GCD013

NE	NE	Section	Township	Range
or Govt Lot #		22	23 N	22 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	72
6	72	123

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No

Rotary - Air .....

No — Rotary - Air & Foam ..... — Yes

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	30
-	-	Z	-	CLAY & STONES	30	72
-	-	L	-	LIMESTONE	72	123

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND STEEL P.E. 18.97 PER FT. BLACK NEW ASTM-A-53-B MADE IN USA	Surface	72
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

42 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	72	S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
KG		12-03-2008
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100
Building Overhang		30

Type	Qualifier	Distance
Clearwater Sump		30
Foundation Drain to Clearwater		30
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 01-20-2009 Updated On: 11-21-2019 Review Status: