Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UU098

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	MAGNIN, GEORGE
Phone #	
Mailing Address	301 COLUMBUS DR
City	MARSHFIELD
State	WI
Zip Code	54449
County	Ashland
Co. Permit #	
Notification #	
Completed	10-31-2005
Well Constructor (Business Name)	BUTTERFIELD, THOMAS G
Lic. #	555
Facility ID # (Public Wells)	
Address	6380 N COUNTY RD E STONE LAKE WI 54876
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	0

1. Well Location

Town of	MORSE
Fire # (if avail.)	
Street Address or Road Name and Number	BUTLER RD
Subdivision Name	
Lot #	
Block #	
Latitude / Longitude in Decimal Degree (DD)	°N °W
Method Code	
SE NE or Govt Lot #	
Section	32
Township	45 N
Range	2 W

2. Well Type Reconstruction

of previous unique well # UK15 constructed in 2005

Reason for replaced or reconstructed well ?

Construction Type Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9.8	Surface	40
6	40	362

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	B	CLAY W/GRAVEL/COBBLES/BOULDERS/STONES	Surface	40
-	-	Q	-	GRANITE	40	362

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW P&E BLACK WELDED 18.97 LB/FT ASTM A53B SAWHILL	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
VOLCLAY GROUT	Surface	40	

9. Static Water Level

12 ft. below ground surface

10. Pump Test

Pumping level 180 ft. below surface

Pumping at 0.8 GP for 1 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

N/A

13. Constructor / Supervisory Driller	Lic #	Date Signed
TB		03-17-2009
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		35

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	10/05/2009	3/8 CHIPS 0-150, 34 SACKS; 3/8 PEAROCK 150-362', 1 1/2 YDS USED	SALT WATER

Created On: 12-07-2009 Updated On: 03-17-2010 Review Status: