Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UU768

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: K MANAGEMENT LLC	Phone #: (608)837-7800
Mailing Address: 7190 ELDER LN	
City: SUN PRAIRIE	State: WI Zip Code: 53590
County: Dane	Co. Permit #: 183
Notification #: 6913672901	Completed: 08-17-2017
Well Constructor (Business Name): WATER WELLS INC	Lic. #: 3
Facility ID # (Public Wells)	
Address: 6400 LAKE RD WINDSOR WI 53598-9717	
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 0.4	

1. Well Location

Fire # (if avail.)

Town of BRISTOL

Street Address or Road Name and Number: 7190 ELDER LN

Subdivision Name | Lot # | Block #

Latitude / Longitude in Decimal Degree (DD): 43.2366 °N -89.1535 °W

Method Code: GCD013

NW NE or Govt Lot # | Section: 23 | Township: 9 N | Range: 11 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of BUILDING-INDUSTRY

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	61
6	61	115

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	7
-	-	C	G	STONEY CLAY	7	35
-	-	L	-	LIMESTONE	35	87
T	-	N	-	TAN S.S.	87	96
I	-	N	-	TAN & WHITE S.S.	96	113
E	-	N	-	WHITE & GREEN S.S.	113	115

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BL PE ASTM A-53 GR B SAWHILL	Surface	61
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method: BRAIDENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	61	15 S

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 20 GP M for 2.1 Hrs.

Pumping Method ?

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
MAB		08-29-2017
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		35

Comment:

Created On: 10-18-2017 Updated On: 12-11-2019 Review Status: