

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UU768		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner K MANAGEMENT LLC						Phone # (608)837-7800		1. Well Location				Fire # (if avail.)					
Mailing Address 7190 ELDER LN								Town of BRISTOL									
City SUN PRAIRIE						State WI		Zip Code 53590									
County Dane		Co. Permit # 183		Notification # 6913672901		Completed 08-17-2017		Subdivision Name				Lot #					
												Block #					
Well Constructor (Business Name) WATER WELLS INC				Lic. # 3		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.2366 °N -89.1535 °W							
						Well Plan Approval #				Method Code GCD013							
Address 6400 LAKE RD WINDSOR WI 53598-9717						Approval Date (mm-dd-yyyy)				NW NE Section Township Range or Govt Lot # 23 9 N 11 E							
Hicap Permanent Well #				Common Well #		Specific Capacity 0.4				2. Well Type New Well							
										of previous unique well # constructed in							
										Reason for replaced or reconstructed well ?							
3. Well serves 1 # of BUILDING-INDUSTRY				Hicap Well ? No						Construction Type Drilled							
Private, potable				Hicap Property ? No													
Heat Exchange ___ # of drillholes				Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		61		Yes Rotary - Mud Circulation		No		- - C -		CLAY		Surface		7	
6		61		115		No Rotary - Air		No		- - C G		STONEY CLAY		7		35	
						No Rotary - Air & Foam		No		- - L -		LIMESTONE		35		87	
						No Drill-Through Casing Hammer				T - N -		TAN S.S.		87		96	
						No Reverse Rotary				I - N -		TAN & WHITE S.S.		96		113	
						No Cable-tool Bit ___ in. dia...		No		E - N -		WHITE & GREEN S.S.		113		115	
						No Dual Rotary		No									
						No Temp. Outer Casing ___ in. dia											
						No Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level				11. Well Is			
6		BL PE ASTM A-53 GR B SAWHILL				Surface		61		15 ft. below ground surface				20 in. above grade			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				Developed ? Yes			
										Pumping level 60 ft. below surface				Disinfected ? Yes			
										Pumping at 20 GP M for 2.1 Hrs.				Capped ? Yes			
										Pumping Method ?							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? No					
Method		BRAIDENHEAD															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement											
NEAT CEMENT		Surface		61		15 S		Filled & Sealed Well(s) as needed? No									
												13. Constructor / Supervisory Driller					
												Lic #		Date Signed			
												MAB		08-29-2017			
												Drill Rig Operator		Lic or Reg #			
														Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		35

Comment:

Created On: 10-18-2017

Updated On: 12-11-2019

Review Status: