Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UV586

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SIMONSON, DALE	Phone #: (608)269-3882
Mailing Address: 16151 CO HWY A	
City: SPARTA	State: WI — Zip Code: 54656
County: Monroe	Co. Permit #:
Notification #: 38608619	Completed: 10-25-2010
Well Constructor (Business Name): GENE H MAURER	Lic. #: 296
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: MAURER WELL DRILLING LLC BLACK RIVER FALLS WI 54615-9804	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 2	

1. Well Location

Town of ADRIAN	Fire # (if avail.): 16098
Street Address or Road Name and Number: CO HWY A	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.9305 °N -90.6676 °W	Method Code: GCD013
SW SW or Govt Lot #	Section: 19 — Township: 17 N — Range: 2 W

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: SAND POINT PLUGGED

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ?

Hicap Property ?

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	38

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — No
- Rotary - Air & Foam .....
- Yes — Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T - I -	BROWN TOPSOIL	Surface	2
T Q S -	CAVING TAN SAND	2	15
T Q X -	CAVING TAN SAND & CLAY	15	22
T Q S -	CAVING TAN SAND	22	38

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL 18.97-ASTM A53 WELDED-IPSCO USA	Surface	32
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	STAINLESS STEEL-TELESCOPE-10 SLOT	32	38

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level

12 ft. below ground surface

10. Pump Test

Pumping level 18 ft. below surface

Pumping at 12 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

21 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
GM		10-29-2010
Drill Rig Operator	Lic or Reg #	Date Signed
MM		10-29-2010

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		85	Sewer - Building Sanitary		39
Building Overhang		12	Septic or Holding, or POWTS Tank		35

Comment:

Created On: 11-17-2010 Updated On: 04-29-2020 Review Status: