

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UV586		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner SIMONSON, DALE						Phone # (608)269-3882		1. Well Location				Fire # (if avail.)					
Mailing Address 16151 CO HWY A						Town of ADRIAN						16098					
City SPARTA						State WI		Zip Code 54656				Street Address or Road Name and Number					
County Monroe						Co. Permit #		Notification # 38608619		Completed 10-25-2010		Subdivision Name		Lot #		Block #	
Well Constructor (Business Name) GENE H MAURER						Lic. # 296		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.9305 °N -90.6676 °W				Method Code GCD013			
Address MAURER WELL DRILLING LLC BLACK RIVER FALLS WI 54615-9804						Well Plan Approval #		Approval Date (mm-dd-yyyy)		SW SW		Section 19		Township 17 N		Range 2 W	
										or Govt Lot #							
Hicap Permanent Well #						Common Well #		Specific Capacity 2		2. Well Type Replacement							
Reason for replaced or reconstructed well ?						SAND POINT PLUGGED											
3. Well serves 1 # of						Hicap Well ?		Construction Type Drilled									
Private, potable						Hicap Property ?											
Heat Exchange ___ # of drillholes						Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock							
6		Surface		38		Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>No</u> Rotary - Air & Foam <u>Yes</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)											
8. Geology																	
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)							
T - I -		BROWN TOPSOIL						Surface		2							
T Q S -		CAVING TAN SAND						2		15							
T Q X -		CAVING TAN SAND & CLAY						15		22							
T Q S -		CAVING TAN SAND						22		38							
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level							
6		BLACK STEEL 18.97-ASTM A53 WELDED-IPSCO USA				Surface		32		12 ft. below ground surface							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is							
5		STAINLESS STEEL-TELESCOPE-10 SLOT				32		38		21 in. above grade							
7. Grout or Other Sealing Material										10. Pump Test							
Method										Pumping level 18 ft. below surface							
Kind of Sealing Material										Pumping at 12 GP M for 2 Hrs.							
From (ft.) To (ft.) # Sacks Cement										Pumping Method ?							
Surface										Filled & Sealed Well(s) as needed? Yes							
13. Constructor / Supervisory Driller										Lic #		Date Signed					
GM												10-29-2010					
Drill Rig Operator										Lic or Reg #		Date Signed					
MM												10-29-2010					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		85	Sewer - Building Sanitary		39
Building Overhang		12	Septic or Holding, or POWTS Tank		35

Comment:

Created On: 11-17-2010

Updated On: 04-29-2020

Review Status: