

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UV589		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A															
Property Owner WASKO, MATT						Phone # (815)941-9474		1. Well Location				Fire # (if avail.)													
Mailing Address 640 E SOUTHMOR RD						Town of MANCHESTER						Street Address or Road Name and Number CO RD O													
City MORRIS				State IL		Zip Code 60450																			
County Jackson		Co. Permit #		Notification # 39081959		Completed 11-29-2010		Subdivision Name				Lot #		Block #											
Well Constructor (Business Name) GENE H MAURER				Lic. # 296		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code											
Address N7869 W SNOW CREEK RD BLACK RIVER FALLS WI 54615-9804				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SE NE Section Township Range or Govt Lot # 26 20 N 3 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled															
								Hicap Permanent Well #						Common Well #		Specific Capacity 2									
3. Well serves 1 # of CAMPSITE Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?																					
4. Potential Contamination Sources - ON REVERSE SIDE																									
5. Drillhole Dimensions and Construction Method														8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
6		Surface		42		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				T Q I - CAVING BROWN TOPSOIL T Q S - CAVING TAN SAND				Surface		2									
6		BLACK STEEL 18.97 ASTM A53 WELDED IPSCO USA		Surface										37		2		42							
Dia. (in.)		Screen type, material & slot size		From (ft.)										To (ft.)		11. Well Is 20 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes									
5		SS TELESCOPE 10 SLOT		37										42											
5		SS TELESCOPE 10 SLOT		37										42											
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is 20 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		20 ft. below ground surface															
6		BLACK STEEL 18.97 ASTM A53 WELDED IPSCO USA				Surface		37		10. Pump Test Pumping level 26 ft. below surface Pumping at 12 GP for 1.5 Hrs. Pumping Method ?															
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?															
5		SS TELESCOPE 10 SLOT				37		42																	
7. Grout or Other Sealing Material														13. Constructor / Supervisory Driller				Lic #				Date Signed			
Method																									
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement				GM Drill Rig Operator MM				Lic or Reg #				Date Signed					
Surface				Surface		Surface		Surface																	

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment: NO BLDG OVERHANG, SEPTIC/SEWER, & BLDG SEWER

Created On: 01-11-2011

Updated On: 02-15-2011

Review Status: