Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UV589

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WASKO, MATT	Phone #: (815)941-9474
Mailing Address: 640 E SOUTHMOR RD	
City: MORRIS	State: IL — Zip Code: 60450
County: Jackson	Co. Permit #:
Notification #: 39081959	Completed: 11-29-2010
Well Constructor (Business Name): GENE H MAURER	Lic. #: 296
Facility ID # (Public Wells):	
Address: N7869 W SNOW CREEK RD BLACK RIVER FALLS WI 54615-9804	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 2	

1. Well Location

Town of MANCHESTER

Fire # (if avail.):

Street Address or Road Name and Number: CO RD O

Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:
SE NE or Govt Lot #:	Section: 26	Township: 20 N	Range: 3 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of CAMPSITE

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?:

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	42

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T Q I -	CAVING BROWN TOPSOIL	Surface	2
T Q S -	CAVING TAN SAND	2	42

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL 18.97 ASTM A53 WELDED IPSCO USA	Surface	37
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	SS TELESCOPE 10 SLOT	37	42

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 26 ft. below surface

Pumping at 12 GP for 1.5 Hrs.

Pumping Method ?:

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

12. Notified Owner of need to fill & seal ?:

Filled & Sealed Well(s) as needed?:

13. Constructor / Supervisory Driller	Lic #	Date Signed
GM		12-20-2010
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MM		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: NO BLDG OVERHANG, SEPTIC/SEWER, & BLDG SEWER

Created On: 01-11-2011 Updated On: 02-15-2011 Review Status: