Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UV776

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PETERSON, BRUCE	Phone #: (715)653-2394
Mailing Address: 22722 JOHNSON RD	
City: FREDERIC	State: WI — Zip Code: 54837
County: Burnett	Co. Permit #:
Notification #: 37621693	Completed: 07-16-2010
Well Constructor (Business Name): DANIEL J BEECROFT	Lic. #: 602
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: DAN WELL CO FREDERIC WI 54837	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.8	

1. Well Location

Town of LA FOLLETTE

Fire # (if avail.):

Street Address or Road Name and Number: 22722 JOHNSON RD

Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:
SE NE or Govt Lot #:	Section: 35	Township: 38 N	Range: 15 W

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: LOW YIELD

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	111

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	S	SANDY CLAY	Surface	5
-	-	C	G	GRAVELY CLAY	5	10
-	-	G	S	SANDY GRAVEL	10	35
-	-	P	-	HARDPAN	35	55
-	-	G	S	DIRTY SANDY GRAVEL	55	85
-	S	N	-	SOFT SANDROCK	85	111

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53 IPSCO PLN END BT WLD	Surface	103.333
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	#10 JOHNSON SS 103.333-106.5; #12 JOHNSON SS 106.5-111.	103.333	111

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRAN BENTONITE	Surface		

9. Static Water Level

30 ft. below ground surface

10. Pump Test

Pumping level 55 ft. below surface

Pumping at 20 GP for 1 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DJB		07-20-2010
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
BB		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Shoreline/Pool	>	200
Building Overhang		10	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 08-06-2010 Updated On: 08-06-2010 Review Status: