

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UV776		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner PETERSON, BRUCE						Phone # (715)653-2394		1. Well Location				Fire # (if avail.)	
Mailing Address 22722 JOHNSON RD						Town of LA FOLLETTE							
City FREDERIC						State WI		Zip Code 54837					
County Burnett		Co. Permit #		Notification # 37621693		Completed 07-16-2010		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) DANIEL J BEECROFT				Lic. # 602		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code	
Address DAN WELL CO FREDERIC WI 54837				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 35 38 N 15 W		2. Well Type Replacement				of previous unique well # constructed in	
Hicap Permanent Well #		Common Well #		Specific Capacity 0.8		Reason for replaced or reconstructed well ? LOW YIELD							
3. Well serves 1 # of Private, potable				Hicap Well ? No		Construction Type Drilled							
Heat Exchange ___ # of drillholes				Hicap Property ? No									
Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock			
6		Surface		111									
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)							
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		A53 IPSCO PLN END BT WLD				Surface		103.333					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
4		#10 JOHNSON SS 103.333-106.5; #12 JOHNSON SS 106.5-111.				103.333		111					
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
GRAN BENTONITE				Surface									
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
-	-	C	S	SANDY CLAY		Surface		5					
-	-	C	G	GRAVELY CLAY		5		10					
-	-	G	S	SANDY GRAVEL		10		35					
-	-	P	-	HARDPAN		35		55					
-	-	G	S	DIRTY SANDY GRAVEL		55		85					
-	S	N	-	SOFT SANDROCK		85		111					
9. Static Water Level													
30 ft. below ground surface													
10. Pump Test													
Pumping level 55 ft. below surface													
Pumping at 20 GP for 1 Hrs.													
Pumping Method ?													
11. Well Is													
14 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?												Yes	
13. Constructor / Supervisory Driller													
DJB												Date Signed 07-20-2010	
Drill Rig Operator												Lic or Reg #	
BB												Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Shoreline/Pool	>	200
Building Overhang		10	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 08-06-2010

Updated On: 08-06-2010

Review Status: