

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UV784		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner ERICKSON, RUSS					Phone # (715)566-3850		1. Well Location				Fire # (if avail.)			
Mailing Address 3162 50TH ST							Town of LORAIN							
City FREDERIC					State WI		Zip Code 54837							
County Polk		Co. Permit #		Notification # 37819510		Completed 08-15-2010		Subdivision Name				Lot # Block #		
Well Constructor (Business Name) DANIEL J BEECROFT					Lic. # 602		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.6636 °N -92.2555 °W		Method Code GCD013	
Address DAN WELL CO FREDERIC WI 54837					Well Plan Approval #		NW NW		Section 29		Township 37 N		Range 15 W	
Hicap Permanent Well #					Common Well #		Specific Capacity 2				2. Well Type Reconstruction			
Heat Exchange ___ # of drillholes					Hicap Well ? No		Hicap Property ? No				Reason for replaced or reconstructed well ? PUMPED SAND			
Heat Exchange ___ # of drillholes					Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock											
6 Surface 98.42			Rotary - Mud Circulation											
4 98.42 175			Rotary - Air											
			Rotary - Air & Foam											
			Drill-Through Casing Hammer											
			Reverse Rotary											
			Cable-tool Bit ___ in. dia...											
			Dual Rotary											
			Temp. Outer Casing ___ in. dia											
			Removed? ___ depth ft. (If NO explain on back side)											
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
- - Z S				SANDY/GRAVELY CLAY & ROCKS				Surface		35				
- - S -				SAND				35		90				
- - H -				LAYERED HARD & SOFT SHALE				90		160				
- H H -				HARD SHALE				160		175				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		A53 IPSCO BLK PLN-END. BT. WELD				Surface		98.42						
4		A53 IPSCO BLK PLN END BT. WLD.				98.42		162.5						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
7. Grout or Other Sealing Material														
Method MOUNDED														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
GRAN. BENTONITE				Surface										
9. Static Water Level														
90 ft. below ground surface														
10. Pump Test														
Pumping level 100 ft. below surface														
Pumping at 20 GP M for 4 Hrs.														
Pumping Method ?														
11. Well Is														
15 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ?														
Filled & Sealed Well(s) as needed?														
13. Constructor / Supervisory Driller														
DTB				Lic #		Date Signed								
DTB						08-15-2010								
Drill Rig Operator				Lic or Reg #		Date Signed								
BB						08-15-2010								

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Building Overhang		3
			Septic or Holding, or POWTS Tank		90

Comment:

Created On: 11-11-2010

Updated On: 06-30-2020

Review Status: