Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: UV789

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KUHL, LARRY	Phone #: (715)822-5300
Mailing Address: 2112 13 1/4 ST	
City: CUMBERLAND	State: WI — Zip Code: 54829
County: Barron	Co. Permit #:
Notification #: 38435753	Completed: 10-05-2010
Well Constructor (Business Name): DANIEL J BEECROFT	Lic. #: 602
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: DAN WELL CO, FREDERIC WI 54837	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.7	

1. Well Location

Town of STANFOLD

Fire # (if avail.):

Street Address or Road Name and Number: 2112 13 1/4 ST

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 45.5115 °N -91.8861 °W

Method Code: GCD013

SW or Govt Lot #	SW	Section: 17	Township: 35 N	Range: 12 W

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: LOW YIELD

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
5	Surface	63

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit ____in. dia... — No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	S	SANDY LOAM	Surface	4
-	-	S	-	SAND	4	25
-	-	X	U	DIRTY SAND & CLAY	25	55
-	-	Y	-	SAND & GRAVEL	55	63

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	IPSCO ASTM A53 BLK. PLN. END. BT. WELD	Surface	59
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	JOHNSON SS. #18	59	63

9. Static Water Level

23 ft. below ground surface

10. Pump Test

Pumping level 45 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

15 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULATED BENTONITE	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
BB		10-05-2010
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65

Type	Qualifier	Distance
Building Overhang		2
Septic or Holding, or POWTS Tank		60

Comment:

Created On: 11-11-2010 Updated On: 06-18-2020 Review Status: