Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UX197

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner	TEMBY, TIM & LISA %PORTSIDE BUIL
Phone #	
Mailing Address	810 S LANSING AVE
City	STURGEON BAY
State	WI
Zip Code	54235

County	Co. Permit #	Notification #	Completed
Door		57353157	12-11-2015

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
CHARLIES PUMPS & WELL DRILLING INC	143	

Address 1122 ROOSEVELT CT
BRUSSELS WI 54204-9553

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.1

3. Well serves 1 # of home
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Fire # (if avail.) 5682

Town of JACKSONPORT

Street Address or Road Name and Number
5682 CLARKS LAKE DR

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.9456 °N	-87.20365 °W			GPS006

SE NW or Govt Lot #	Section	Township	Range
	34	29 N	27 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9.87	Surface	49
8	49	140
6	140	263

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 8in. dia	
Yes	Removed? 49depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	Y	-	Tan/Brown, Caving, Sand & Gravel	Surface	16
G	V	C	-	Gray, Non-Caving, Clay	16	47
I	H	L	-	White, Hard/Firm, Limestone/Dolomite	47	263

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND WR USA ASTM A53/ASME SA53 6.625 X .280 GR BE NSF-61 21' NEW BLACK	Surface	140
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
1 ft. below ground surface

10. Pump Test
Pumping level 140 ft. below surface
Pumping at 10 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method Bradenhead

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Neat cement grout	Surface	140	56 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RM		12-31-2015
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Foundation Drain to Clearwater		14	Sewer - Building Sanitary		14
			Septic or Holding, or POWTS Tank		30

Comment:

Created On: 01-12-2016 Updated On: 12-03-2019 Review Status: APPROVED