Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UX231

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SPOOER, DAVID	Phone #: (715)723-2543
Mailing Address: 13406 81ST AVE	
City: CHIPPEWA FALLS	State: WI — Zip Code: 54729
County: Chippewa	Co. Permit #: 32186 — Notification #: 49729356 — Completed: 11-20-2013
Well Constructor (Business Name): JOHN J HATFIELD	Lic. #: 4934 — Facility ID # (Public Wells):
Address: HATFIELD PUMP INSTALLERS, STANLEY WI 54768-9802	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 20

1. Well Location

Town of EAGLE POINT	Fire # (if avail.): 13406
Street Address or Road Name and Number: 13406 81ST AVE CHIPPEWA FALLS	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.9595 °N -91.3978 °W	Method Code: GCD013
SW SE or Govt Lot #:	Section: 30 — Township: 29 N — Range: 8 W

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: OLD POINT WELL SHUT DOWN

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	32

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 6in. dia... — No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	25
-	-	S	G	SAND & GRAVEL	25	39

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD BLACK STEEL WELDED PLAIN END 1897 ASTM-A-53-IPSCO U.S.A.	Surface	32
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

8 ft. below ground surface

10. Pump Test

Pumping level 9 ft. below surface

Pumping at 20 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENITE	Surface	32	S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JJH		12-11-2013
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Shoreline/Pool		130
			Septic or Holding, or POWTS Tank		45

Comment:

Created On: 10-17-2014 Updated On: 06-11-2020 Review Status: