Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UX232

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TIRY, JOE			Phone #: (715)644-2538
Mailing Address: 34111 CO RD O			
City: STANLEY	State: WI	Zip Code: 54768	
County: Chippewa	Co. Permit #: 32278	Notification #: 52400410	Completed: 12-02-2013

Well Constructor (Business Name): JOHN J HATFIELD	Lic. #: 4934	Facility ID # (Public Wells):	
Address: HATFIELD PUMP INSTALLERS STANLEY WI 54768		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1	

3. Well serves 1 # of BARN & HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of DELMAR				Fire # (if avail.): 34111
Street Address or Road Name and Number: CO RD O				
Subdivision Name			Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): 44.964 °N -90.9812 °W				Method Code: GCD013
NE SW or Govt Lot #	Section: 27	Township: 29 N	Range: 5 W	

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
4IN WELL LOW VOLUME

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	20
6	20	70

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit ____in. dia... No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	43
-	-	N	-	SAND-ROCK	43	70

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD. BLACK STEEL WELDED-PLAIN-END AS.T.M.-A-53-IPESCO	Surface	48
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
50 ft. below ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 10 GP M for 4 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	20	S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JJH		12-17-2013
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		110
Manure Hopper or Reception Tank - Liquid Tight		347
Building Overhang		40
Buried Petroleum Tank		129
Silo/Storage Tube		180
Barn Gutter		186
Septic or Holding, or POWTS Tank		59

Comment:

Created On: 09-11-2014 Updated On: 06-11-2020 Review Status: