

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UX232		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner TIRY, JOE						Phone # (715)644-2538		1. Well Location				Fire # (if avail.)			
Mailing Address 34111 CO RD O						Town of DELMAR						34111			
City STANLEY						State WI		Zip Code 54768				Street Address or Road Name and Number CO RD O			
County Chippewa		Co. Permit # 32278		Notification # 52400410		Completed 12-02-2013		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) JOHN J HATFIELD				Lic. # 4934		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.964 °N -90.9812 °W				Method Code GCD013	
Address HATFIELD PUMP INSTALLERS STANLEY WI 54768				Well Plan Approval #		NE SW		Section 27		Township 29 N		Range 5 W			
				Approval Date (mm-dd-yyyy)		or Govt Lot #									
Hicap Permanent Well #		Common Well #		Specific Capacity 1		2. Well Type Replacement				of previous unique well # constructed in					
Reason for replaced or reconstructed well ? 4IN WELL LOW VOLUME				Hicap Well ? No		Hicap Property ? No		Hicap Potable ?		Construction Type Drilled					
Private, potable				Heat Exchange ___ # of drillholes											
3. Well serves 1 # of BARN & HOME															
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
8		Surface		20		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
6		20		70											
6. Casing, Liner, Screen						8. Geology				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		50 ft. below ground surface					
6		STD. BLACK STEEL WELDED-PLAIN-END AS.T.M.-A-53-IPESCO				Surface		48		10. Pump Test					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Developed ? Yes					
										Disinfected ? Yes					
										Capped ? Yes					
7. Grout or Other Sealing Material						9. Static Water Level				18 in. above grade					
Method						50 ft. below ground surface				Pumping level 60 ft. below surface					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		Pumping at 10 GP M for 4 Hrs.				Pumping Method ?			
CLAY SLURRY		Surface		20		S		12. Notified Owner of need to fill & seal ?				Filled & Sealed Well(s) as needed? Yes			
						13. Constructor / Supervisory Driller				Lic #		Date Signed			
						JJH						12-17-2013			
						Drill Rig Operator				Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		110	Buried Petroleum Tank		129
Manure Hopper or Reception Tank - Liquid Tight		347	Silo/Storage Tube		180
Building Overhang		40	Barn Gutter		186
			Septic or Holding, or POWTS Tank		59

Comment:

Created On: 09-11-2014

Updated On: 06-11-2020

Review Status: