

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UX233		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner CORNELL, LARRY						Phone # (715)644-3619		1. Well Location				Fire # (if avail.)											
Mailing Address 12107 CO RD H						Town of DELMAR						12107											
City STANLEY						State WI		Zip Code 54768				Street Address or Road Name and Number 12107 CO TRUNK H											
County Chippewa		Co. Permit # 32259		Notification # 52163877		Completed 07-14-2014		Subdivision Name				Lot # Block #											
Well Constructor (Business Name) JOHN J HATFIELD				Lic. # 4934		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.01817 °N -90.93242 °W				Method Code GPS008											
Address HATFIELD PUMP INSTALLERS STANLEY WI 54768-9802				Well Plan Approval #		SW SE Section Township Range or Govt Lot # 1 29 N 5 W		2. Well Type Replacement				of previous unique well # constructed in											
Hicap Permanent Well #		Common Well #		Specific Capacity 0.2		Reason for replaced or reconstructed well ? OLD 4INCH WELL																	
3. Well serves 1 # of Private, potable				Hicap Well ? No		Construction Type Drilled																	
Heat Exchange ___ # of drillholes				Hicap Property ? No																			
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method																							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)							
8		Surface		8		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		No		- - - C		CLAY		Surface		8							
6		8		61						- - - S		SAND		8		23							
										- - C P		CLAY (HARDPAN)		23		40							
										- - S C		SAND & CLAY		40		50							
										- - - S		SAND		50		55							
										- - - N		SANDROCK		55		58							
										- - N S		SANDROCK (FINE)		58		61							
6. Casing, Liner, Screen												8. Geology											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 35 ft. below ground surface				11. Well Is 12 in. above grade									
6		STD. BLACK STEEL WELDED-PLAIN-END ASTM-A53-IPESCO.USA				Surface		59		10. Pump Test Pumping level 56 ft. below surface Pumping at 4 GP M for 4 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes													
7. Grout or Other Sealing Material Method												13. Constructor / Supervisory Driller				Lic #				Date Signed			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		JJH				07-14-2014									
CLAY-SLURRY				Surface		8		S		Drill Rig Operator				Lic or Reg #				Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Downspout/Yard Hydrant		35
Building Overhang		20	Septic or Holding, or POWTS Tank		51

Comment:

Created On: 08-26-2014

Updated On: 08-26-2014

Review Status: