

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UY852		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner STEFFAN, DUSTIN						Phone # 9371858		1. Well Location				Fire # (if avail.)									
Mailing Address 7818 185TH ST						Town of LAFAYETTE															
City CHIPPEWA FALLS						State WI		Zip Code 54729				Street Address or Road Name and Number 7818 185TH									
County Chippewa		Co. Permit # 30053		Notification # 34598041		Completed 10-01-2009		Subdivision Name PINE HARBOR				Lot # Block #									
Well Constructor (Business Name) CHRISTOPHER J OLSON				Lic. # 5820		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.9558 °N -91.2976 °W				Method Code GCD013							
Address OLSON BROS WELL DRLG EAU CLAIRE WI 54701				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 36 29 N 8 W				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
						Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 1.1																	
3. Well serves 1 # of CHURCH Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		39		Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>Yes</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia Removed? 17depth ft. (If NO explain on back side)								T - X -		BRN SAND & CLAY		Surface		17	
6		39		60										T - N -		TAN SANDSTONE		17		60	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		27 ft. below ground surface				16 in. above grade							
6		A53B USA PE STEEL 280 WALL WELDED JOINTS				Surface		57		10. Pump Test Pumping level 36 ft. below surface Pumping at 10 GP for 1 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
6		TEL S STEEL 010 SLOT				57		60													
7. Grout or Other Sealing Material Method TREMIE PUMPED														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No NA							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement													
NEAT CEMENT				Surface		39		12 S		13. Constructor / Supervisory Driller Lic # Date Signed CJO Drill Rig Operator Lic or Reg # Date Signed											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		3	Privy		50
Other Contamination Sources		50	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 03-01-2010

Updated On: 06-11-2020

Review Status: