Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UY852

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: STEFFAN, DUSTIN	Phone #: 9371858
Mailing Address: 7818 185TH ST	
City: CHIPPEWA FALLS	State: WI — Zip Code: 54729
County: Chippewa	Co. Permit #: 30053 — Notification #: 34598041 — Completed: 10-01-2009
Well Constructor (Business Name): CHRISTOPHER J OLSON	Lic #: 5820 — Facility ID # (Public Wells):
Address: OLSON BROS WELL DRLG, EAU CLAIRE WI 54701	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.1

1. Well Location

Town of LAFAYETTE

Fire # (if avail.):

Street Address or Road Name and Number: 7818 185TH

Subdivision Name: PINE HARBOR	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 44.9558 °N -91.2976 °W — Method Code: GCD013

NW or Govt Lot #	NE	Section	Township	Range
		36	29 N	8 W

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of CHURCH

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	39
6	39	60

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes / No — Rotary - Air .....
- No / Yes — Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
  Removed? 17depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T - X -	BRN SAND & CLAY	Surface	17
T - N -	TAN SANDSTONE	17	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53B USA PE STEEL 280 WALL WELDED JOINTS	Surface	57
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	TEL S STEEL 010 SLOT	57	60

9. Static Water Level

27 ft. below ground surface

10. Pump Test

Pumping level 36 ft. below surface

Pumping at 10 GP for 1 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	39	12 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NA

13. Constructor / Supervisory Driller	Lic #	Date Signed
CJO		11-03-2009
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		3	Privy		50
Other Contamination Sources		50	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 03-01-2010 Updated On: 06-11-2020 Review Status: