

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UY856		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner PAKAN, DR. J. M. Phone # (715)834-3541						1. Well Location				Fire # (if avail.)	
Mailing Address 1219 10TH ST W						City of ALTOONA				1219	
City ALTOONA State WI Zip Code 54720						Street Address or Road Name and Number 10TH ST W					
County Eau Claire		Co. Permit # 30289		Notification #		Completed 04-14-2010		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) CHRISTOPHER J OLSON				Lic. # 5820		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.79188 °N -91.44167 °W		Method Code GPS008	
Address PO BOX 1477 EAU CLAIRE WI 54702				Well Plan Approval #		NW NW Section 26 Township 27 N Range 9 W or Govt Lot #		2. Well Type Reconstruction of previous unique well # constructed in Reason for replaced or reconstructed well ? LOW YIELD			
				Approval Date (mm-dd-yyyy)		Construction Type Drilled					
Hicap Permanent Well #		Common Well #		Specific Capacity		3. Well serves 1 # of GARDEN Private, non-potable Heat Exchange ____ # of drillholes					
				Hicap Well ? No Hicap Property ? No Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.) 5		From (ft.) Surface		To (ft.) 135		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology	
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 5in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)				Geology Codes T - N - Type, Caving/Noncaving, Color, Hardness, etc... TAN SANDSTONE (DEEPENED FROM 95-135) From (ft.) Surface To (ft.) 135	
6. Casing, Liner, Screen											
Dia. (in.) 5		Material, Weight, Specification Manufacturer & Method of Assembly STEEL CASING TO				From (ft.) Surface		To (ft.) 50		9. Static Water Level ____ ft. ____ ground surface	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test Pumping level ____ ft. below surface Pumping at ____ GP for ____ Hrs. Pumping Method ?	
										11. Well Is 8 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes	
7. Grout or Other Sealing Material											
Method											
Kind of Sealing Material		From (ft.) Surface		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No			
13. Constructor / Supervisory Driller											
CJO						Lic #		Date Signed			
Drill Rig Operator						Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Sewer - Building Sanitary		30

Comment: WELL DRLR DOESN'T HAVE LICENSE. CAN'T GET MISSING INFO.

Variance ID	Variance or Exception Type	Date	Reason
	Well Construction	09/22/2011	RECONSTRUCT A 5" DIAMETER BEDROCK WELL

Created On: 10-03-2012

Updated On: 10-12-2012

Review Status: