

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UY858		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner WOODLEY, MERLIN						Phone # (715)832-9809		1. Well Location				Fire # (if avail.)			
Mailing Address 3028 N 50TH AVE						Town of SEYMOUR						3028			
City CHIPPEWA FALLS						State WI		Zip Code 54701				Street Address or Road Name and Number 3028 N 50TH AVE			
County Eau Claire		Co. Permit # 31023		Notification # 40978268		Completed 07-13-2011		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) CHRISTOPHER J OLSON				Lic. # 5820		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code			
Address OLSON BROS WELL DRLG EAU CLAIRE WI 54701				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 2 27 N 9 W		2. Well Type New Well				of previous unique well # constructed in			
Hicap Permanent Well #		Common Well #		Specific Capacity 0.5		Reason for replaced or reconstructed well ?				Construction Type Drilled					
3. Well serves 1 # of POLE SHED Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) 6		From (ft.) Surface		To (ft.) 150		Upper Enlarged Drillhole Lower Open Bedrock Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit 6in. dia... Yes Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
- - X -		SAND & CLAY				Surface		36							
T - N -		TAN SAND STONE				36		150							
6. Casing, Liner, Screen															
Dia. (in.) 6		Material, Weight, Specification Manufacturer & Method of Assembly A53B PRIME USA IPSCO STEEL P.E. .280 WALL 18.97' WELDED JOINTS				From (ft.) Surface		To (ft.) 36							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material BENTONITE CASING SEAL		From (ft.) Surface		To (ft.) 12		# Sacks Cement 4 S									
9. Static Water Level															
63 ft. below ground surface															
10. Pump Test															
Pumping level 128 ft. below surface Pumping at 30 GP M for 12 Hrs. Pumping Method ?															
11. Well Is															
18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? No N.A.															
13. Constructor / Supervisory Driller															
CJO		Lic #		Date Signed 09-04-2011		Drill Rig Operator		Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Building Overhang		10
			Septic or Holding, or POWTS Tank	>	100

Comment:

Created On: 12-19-2011

Updated On: 12-19-2011

Review Status: