Well Construction Report
WISCONSIN UNIQUE WELL NUMBER VA924

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MILLIS, STEVE	Phone #: (715)299-3399
Mailing Address: W11425 CO RD C	
City: BLACK RIVER FALLS	State: WI — Zip Code: 54615
County: Jackson	Co. Permit #: — Notification #: 35353504 — Completed: 12-02-2009
Well Constructor (Business Name): HEEG WELL DRLG LLC	Lic. #: 6704 — Facility ID # (Public Wells):
Address: 5069 CTY ROAD F, AUBURNDALE WI 54412	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #: — Common Well #: — Specific Capacity: 0.4	

1. Well Location

Town of ADAMS				Fire # (if avail.): W11485
Street Address or Road Name and Number: W11485 FOREST HILLS DR				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 44.3035 °N -90.8799 °W				Method Code: GCD013
NW or Govt Lot #: NW	Section: 16	Township: 21 N	Range: 4 W	

2. Well Type New Well
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	160
6	160	202

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	C	-	CLAY	Surface	3
T	Q	S	-	SAND	3	11
I	H	N	-	SANDSTONE	11	155
G	H	H	-	SHALE	155	202

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STANDARD STEEL ASTM A53 WHEATLAND USA WELDED JOINT	Surface	160
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
145 ft. below ground surface

10. Pump Test
Pumping level 202 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method TREMIE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT	Surface	160	32 S

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? No
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
BH		12-02-2009
Drill Rig Operator	Lic or Reg #	Date Signed
CH		12-02-2009

4a. Potential Contamination Sources Is the well located in floodplain ?

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Building Overhang		60
			Septic or Holding, or POWTS Tank		100

Comment:

Created On: 01-22-2010 Updated On: 05-01-2020 Review Status: