Well Construction Report
WISCONSIN UNIQUE WELL NUMBER VA928

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TRITZ, RODGER	Phone #: (715)884-2166
Mailing Address: 7770 HILLTOP RD	
City: PITTSVILLE	State: WI — Zip Code: 54466
County: Wood	Co. Permit #:
Notification #: 35851377	Completed: 02-05-2010
Well Constructor (Business Name): HEEG WELL DRLG LLC	Lic. #: 6704
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: 5069 CTY ROAD F, AUBURNDALE WI 54412	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0	

1. Well Location

Town of WOOD

Fire # (if avail.):

Street Address or Road Name and Number: 7770 HILLTOP RD

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): 44.46077 °N -90.10395 °W

Method Code: GPS006

SE NE or Govt Lot #: | Section: 23 | Township: 23 N | Range: 3 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	30
6	30	242

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	C	S	SANDY CLAY	Surface	15
I	H	N	-	SANDSTONE	15	37
R	H	Q	-	GRANITE	37	242

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STANDARD STEEL ASTM A53 WHEATLAND USA WELDED JOINT	Surface	30
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

27 ft. below ground surface

10. Pump Test

Pumping level 242 ft. below surface

Pumping at 2 GP for 1 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT	Surface	30	5 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

STILL IN USE

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
CH		02-05-2010

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		200
Building Overhang		40
Animal Barn Pen		300
Silo/Storage Tube		250
Animal Yard - Include Hutches		400
Barn Gutter		300
Septic or Holding, or POWTS Tank		90

Comment: S. JANOWIAK & DRILLER TALKED ABOUT SANDSTONE @ 15, GROUT & CASE TO 30.

Created On: 03-16-2010 Updated On: 04-23-2010 Review Status: