

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				VA928		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner TRITZ, RODGER						Phone # (715)884-2166		1. Well Location				Fire # (if avail.)		
Mailing Address 7770 HILLTOP RD						Town of WOOD								
City PITTSVILLE						State WI		Zip Code 54466				Street Address or Road Name and Number 7770 HILLTOP RD		
County Wood		Co. Permit #		Notification # 35851377		Completed 02-05-2010		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) HEEG WELL DRLG LLC				Lic. # 6704		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.46077 °N -90.10395 °W			Method Code GPS006	
Address 5069 CTY ROAD F AUBURNDAL WI 54412				Well Plan Approval #		SE NE		Section 23		Township 23 N		Range 3 E		
				Approval Date (mm-dd-yyyy)		or Govt Lot #								
Hicap Permanent Well #		Common Well #		Specific Capacity 0		2. Well Type New Well								
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled						
						Hicap Property ? No								
						Hicap Potable ?								
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
8		Surface		30										
6		30		242		Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>Yes</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
T	Q	C	S	SANDY CLAY				Surface		15				
I	H	N	-	SANDSTONE				15		37				
R	H	Q	-	GRANITE				37		242				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		STANDARD STEEL ASTM A53 WHEATLAND USA WELDED JOINT				Surface		30						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
7. Grout or Other Sealing Material														
Method TREMIE PUMPED														
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement								
CEMENT		Surface		30		5 S								
9. Static Water Level														
27 ft. below ground surface														
10. Pump Test														
Pumping level 242 ft. below surface														
Pumping at 2 GP for 1 Hrs.														
Pumping Method ?														
11. Well Is														
24 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ?														
Filled & Sealed Well(s) as needed? No														
STILL IN USE														
13. Constructor / Supervisory Driller								Lic #		Date Signed				
Drill Rig Operator								Lic or Reg #		Date Signed				
CH										02-05-2010				

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		200	Silo/Storage Tube		250
Building Overhang		40	Animal Yard - Include Hutches		400
Animal Barn Pen		300	Barn Gutter		300
			Septic or Holding, or POWTS Tank		90

Comment: S. JANOWIAK & DRILLER TALKED ABOUT SANDSTONE @ 15, GROUT & CASE TO 30.

Created On: 03-16-2010

Updated On: 04-23-2010

Review Status: