Well Construction Report
WISCONSIN UNIQUE WELL NUMBER VC044

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WICKMAN, DAVE			Phone #: (920)833-7846
Mailing Address: N9074 CO HWY X			
City: SEYMOUR	State: WI	Zip Code: 54165	
County: Outagamie	Co. Permit #:	Notification #: 45601519	Completed: 09-27-2012

Well Constructor (Business Name): THOMAS A SCHMIDT	Lic. #: 3966	Facility ID # (Public Wells):	
Address: SCHMIDTS WELL DRILLING, BLACK CREEK WI 54106-9803		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.2	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of CICERO				Fire # (if avail.): N9074
Street Address or Road Name and Number: CO HWY X				
Subdivision Name			Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): 44.56542 °N -88.38653 °W				Method Code: GPS008
NE SW or Govt Lot #	Section: 12	Township: 24 N	Range: 17 E	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	150
6	150	180

Upper Enlarged Drillhole
Yes Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

Lower Open Bedrock
Yes

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R M C C	CLAY	Surface	13
T H L L	LIMESTONE	13	135
T A N	BROWN SANDSTONE	135	180

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL WHEATLAND TEXAS PIPE 18.97# ASTM A53 WELDED-PD DRIVE SHOE	Surface	150
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
60 ft. below ground surface

10. Pump Test
Pumping level 120 ft. below surface
Pumping at 10 GP M for 0.5 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method BRADY HEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	148	36 S

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TAS		10-09-2012
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Building Overhang		37
			Septic or Holding, or POWTS Tank		101

Comment:

Created On: 01-10-2013 Updated On: 02-09-2023 Review Status: