

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				VC044		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner WICKMAN, DAVE						Phone # (920)833-7846		1. Well Location				Fire # (if avail.)	
Mailing Address N9074 CO HWY X						Town of CICERO						N9074	
City SEYMOUR						State WI		Zip Code 54165				Street Address or Road Name and Number	
CO HWY X						Subdivision Name				Lot #		Block #	
County Outagamie		Co. Permit #		Notification # 45601519		Completed 09-27-2012		Latitude / Longitude in Decimal Degree (DD)				Method Code	
Well Constructor (Business Name) THOMAS A SCHMIDT				Lic. # 3966		Facility ID # (Public Wells)				44.56542 °N -88.38653 °W		GPS008	
Address SCHMIDTS WELL DRILLING BLACK CREEK WI 54106-9803				Well Plan Approval #		NE SW		Section 12		Township 24 N		Range 17 E	
				Approval Date (mm-dd-yyyy)		or Govt Lot #							
Hicap Permanent Well #		Common Well #		Specific Capacity 0.2		2. Well Type New Well				of previous unique well # constructed in			
Reason for replaced or reconstructed well ?				Hicap Well ? No		Hicap Property ? No		Hicap Potable ?		Construction Type Drilled			
3. Well serves 1 # of Private, potable				Heat Exchange ___ # of drillholes									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock			
8.75		Surface		150		Yes Rotary - Mud Circulation Yes							
6		150		180		Rotary - Air							
						Rotary - Air & Foam							
						Drill-Through Casing Hammer							
						Reverse Rotary							
						Cable-tool Bit ___ in. dia...							
						Dual Rotary							
						Temp. Outer Casing ___ in. dia							
						Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
R M C C		CLAY		Surface		13							
T H L L		LIMESTONE		13		135							
T A N		BROWN SANDSTONE		135		180							
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		NEW BLACK STEEL WHEATLAND TEXAS PIPE 18.97# ASTM A53 WELDED-PD DRIVE SHOE				Surface		150					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method BRADY HEAD													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
NEAT CEMENT				Surface		148		36 S					
9. Static Water Level													
60 ft. below ground surface													
10. Pump Test													
Pumping level 120 ft. below surface													
Pumping at 10 GP M for 0.5 Hrs.													
Pumping Method ?													
11. Well Is													
24 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? Yes													
13. Constructor / Supervisory Driller													
Lic #				Date Signed									
TAS				10-09-2012									
Drill Rig Operator				Lic or Reg #									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Building Overhang		37
			Septic or Holding, or POWTS Tank		101

Comment:

Created On: 01-10-2013

Updated On: 02-09-2023

Review Status: